

Compliance Statement

No. 2022-708A

Data communication cable, Category 6A

Company

HellermannTyton Data Ltd.
Waterside House,
Edgar Mobbs Way
Northampton NN5 5JE
United Kingdom

Product description

Screened cable (F/FTP) characterized up to 500 MHz
Horizontal floor wiring cable, 100 Ω
4 individually foil screened twisted pairs with overall foil screen
Flame retardant, halogen free

Product identification

CA198 DCA – HTC C6A F/FTP LSZH Dca 4P D500m VI
CA199 – HTC C6A F/FTP LSZH Cca 4P D500m VI
CA200 – HTC C6A F/FTP LSZH Cca 4P B305m VI

Generic cabling and cabling components standards - Category 6A cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-10-1:2012
- TIA-568.2-D:2018

Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report

12232978, DANAK-19/23068

EC Cabling product ID


7180

CS valid until

1 December 2023

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis. This compliance statement has been revised, original issue date 7 November 2022.

Hørsholm, 22 November 2022


Lars Lindskov Pedersen
Test Manager


Dennis Andersen
Head of Department

